



Jeremiah W. (Jay) Nixon, Governor • Sara Parker Pauley, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.mo.gov

July 31, 2015

NOTICE OF VIOLATION 16363SW
CERTIFIED MAIL #7015 0640 0004 9879 5122
RETURN RECEIPT REQUESTED

The Honorable John Best, Mayor
City of Bolivar
345 S. Main Avenue
Bolivar, MO 65613

RE: MISSOURI STATE OPERATING PERMIT NUMBER **MO0022373**

Dear Mayor Best:

A review of your Discharge Monitoring Report(s) (DMR) for the monitoring period ending in **May 2015** shows that the effluent limitations established in your Missouri State Operating Permit (MSOP) have been exceeded. A Notice of Violation (NOV) number **16363SW** is enclosed for exceedances listed below according to your Missouri State Operating Permit (MSOP) number MO0022373. The effluent limits and the values that have exceeded those effluent limits are listed below.

Outfall	Months	Parameter	Permit Limitations	Reported Values
001	05/2015	<i>E Coli</i>	206 MPN/100 mL monthly average	616 MPN/100mL
001	05/2015	Ammonia as N	1.4 mg/L monthly average	3.2 mg/L

An exceedance of the effluent limitations established in your permit is a violation of the Missouri Clean Water Law, Section 644.051.1(3) and 644.076.1, Clean Water Commission Regulation 10 CSR 20-7 and your MSOP. The facility is responsible for taking appropriate steps to eliminate the violation(s).



Recycled Paper

Bolivar WWTF
July 31, 2015
Page 2

Please provide a written response within 15 calendar days of receipt of this letter to the Department of Natural Resources (department) which explains the reason(s) for the non-compliance and what steps your operation has taken or will take to prevent a reoccurrence of the violation(s). The facility will be considered in non-compliance with the violation(s) and our files will reflect the continued non-compliance until the documentation is submitted to this office. If you have already provided this information to the department, you may disregard this request.

We appreciate your cooperation and immediate attention so that violations can be corrected. If you have questions please contact water pollution staff by calling 417-891-4300 or via mail at Missouri Department of Natural Resources, Southwest Regional Office, 2040 W. Woodland, Springfield, MO 65807-5912.

Sincerely,

SOUTHWEST REGIONAL OFFICE



Cynthia S. Davies
Regional Director

CSD/rck

Enclosure